



Pro-Elite Panel Connections



1. 230v supply via a 3amp fused spur.
2. Use either ENCBUS terminals to connect to the equipment to be backed up.
3. Connection to the batteries, 2x12 volt SLA batteries connected in series for 24v.

Battery Installation



The batteries are supplied with lengths of sticky backed Velcro used to secure the batteries in the housing.